



## CERTIFICATE OF CONFORMITY

### CERTIFICATE NUMBER

**018593**

#### Installation Type

**Anti Slip Testing**

#### Area Covered

**Adventure Playground—Ultra Tuff Pool and Deck coating**

#### Address

**Elhap Adventure Playground, 119 Roding Lane North, Woodford Bridge, Essex, IG88NA**

Co-efficient of Friction readings in accordance with the Measurement of Floor Slip Resistance.  
Guidelines recommended by the U.K. Slip-Resistance Group Issue 2 -June 2000

Confirming that all works carried out at the above site conforms to British Standard 7976 part 1 and Health and Safety (guidance) 115. The floor has been tested and have a minimum co-efficient of friction when wet of 51.8 Measured on the TRRL Pendulum portable slip tester, using the 4s slider. Ambient temperature recorded on site was 15°C. The floor therefore complies with the category "Low Potential for slip".

**Certified that the above installation meets the requirements of BS7976 Part 1 as a slip-resistant surface.**

Signature: